

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/25/2013  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155109</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>03/19/2013</b>	
NAME OF PROVIDER OR SUPPLIER  <b>GOLDEN LIVING CENTER-MISHAWAKA</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>811 E 12TH ST</b> <b>MISHAWAKA, IN 46544</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/24/13 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 03/19/13</p> <p>Facility Number: 000045 Provider Number: 155109 AIM Number: 100291400</p> <p>Surveyor: Joe L. Brown, Jr., Life Safety Code Specialist</p> <p>At this PSR survey, Golden Living Center-Mishawaka was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type II (111) construction and fully sprinklered. The 1986 one story therapy addition was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and battery operated smoke detectors in forty one resident sleeping rooms. The facility has a capacity of 85 and had a census of 55 at the time of the survey.</p> <p>All areas where the residents have customary access were sprinklered. All areas providing</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/25/2013  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155109</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>03/19/2013</b>
NAME OF PROVIDER OR SUPPLIER  <b>GOLDEN LIVING CENTER-MISHAWAKA</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>811 E 12TH ST</b> <b>MISHAWAKA, IN 46544</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 facility services were sprinklered, except an unsprinklered garage and shed used for storage.  Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 03/22/13.	{K 000}			